


AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE 1	OF PAGES 2
2. AMENDMENT/MODIFICATION NO. 0002		3. EFFECTIVE DATE 07/29/2010		4. REQUISITION/PURCHASE REQ. NO. SO-10-02444		5. PROJECT NO. (If applicable)
6. ISSUED BY DOT/FEDERAL AVIATION ADMINISTRATION SOUTHER REGION, ASO-52 1701 COLUMBIA AVENUE COLLEGE PARK, GA 30337				7. ADMINISTERED BY (If other than Item 6) DOT/FEDERAL AVIATION ADMINISTRATION SOUTHER REGION, ASO-52 1701 COLUMBIA AVENUE COLLEGE PARK, GA 30337		
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION NO. DTFASO-10-R-00137	
					9B. DATED (SEE ITEM 11) 07/16/2010	
				<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.	
*TO BE COMPLETED BY VENDOR IF NOT COMPLETE					10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
<input type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer is <input type="checkbox"/> extended <input checked="" type="checkbox"/> is not extended.						
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation on as amended, by one of the following methods:						
(a) By completing Item 8 and 15, and returning <u>1</u> copies of the amendment; (b) acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hours and date specified.						
12. ACCOUNTING AND APPROPRIATION DATA (If required)						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT/ORDER NO. IN ITEM 10A.						
<input checked="" type="checkbox"/> B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14.						
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
<input type="checkbox"/> D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) This Amendment to Solicitation DTFASO-10-R-00137 is to provide answers to questions that have been submitted.						
No other changes.						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
				BERTHA RUSSELL		
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
(Signature of person authorized to sign)				BY 		07/29/2010
				(Signature of Contracting Officer)		

1. Question: Is there lightning protection on the roofs now?

Answer: The "A" and "C" roof did but it was removed as some point. The connection points are still there for them to connect to but there are no lightning rods or conductors in place. The "B" didn't have it because it wasn't necessary.

2. Request: Procure a copy of the structural roof plans for the areas of new work...this is needed to better understand the required roof slopes and Insulation

Response: See attached drawings:

ZME Wall Sections
ZME Roof Plan A, B, C
ZME Roof Plan Original

These are drawings indicate the roofs and slopes. The roofs have been re-roofed in the interim so the roof systems have changed from the original systems shown here. The structure has not changed. Note that original insulation design was for 2" of insulation.